

SAFETY AND BUILDINGS DIVISION Plumbing Product Review P.O. Box 2658 Madison, Wisconsin 53701-2658

Jim Doyle, Governor Jack L. Fischer, A.I.A., Secretary

July 29, 2008

ALPHA GENERAL SERVICES, INC. RICHARD J LAPADULA PO BOX 3331 SEBRING FL 33871-3331

Re: Description: SEWAGE TANKS, FIBERGLASS Manufacturer: ALPHA GENERAL SERVICES, INC.

Product Name: 1350 SEPTIC/SEPTIC

Model Number(s): 1350 GAL. FIBERGLASS (2-COMPARTMENT)

[51 IN. L.L., 2 FT. MAX. DEPTH OF BURY; 743 G.P.D. WHEN USED AS A

SEPTIC/SEPTIC TANK]

Product File No: 20080210

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of AUGUST 2013.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- This product must be installed in accordance with the manufacturer's printed instructions, the plan approval and s. Comm 83.15 (4), Wis. Admin. Code. If there is a conflict between the manufacturer's instructions and the plan approval, the plan approval and code requirements will take precedence.
- This product must be installed in accordance with the manufacturer's printed instructions, product approval and the plan approval. If there is a conflict between the manufacturer's instructions and the plan approval, the plan approval will take precedence.
- When this product receives wastewater from dwellings and is used as a septic tank, it will produce an effluent quality with a maximum monthly average value for BOD5 of greater than 30 mg/L and less than or equal to 220 mg/L TSS, or greater than 30 mg/L or less than or equal to 150 mg/L TSS, and F.O.G. of less than 30 mg/L.
- This product must have installed a department-approved effluent filter capable of filtering particles of 1/8 inch in size or larger.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

SBD-10564-E (N.10/97) File Ref: 08021005.DOC

ALPHA GENERAL SERVICES, INC. Page 2 July 29, 2008 PRODUCT FILE NO. 20080210

Sincerely,

Jean M. MacCubbin, CST
Engineering Consultant--Plumbing Product Reviewer
Commerce; Safety & Buildings Div.
PO Box 2658
201 W Washington Ave.
Madison WI 53703-2658

Phone: 608-266-0955; Fax: 608-283-7456 E-mail: Jean.MacCubbin@wisconsin.gov